

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20150474, Building Permit - Commercial  
Address: 600 SW JEFFERSON ST, Unit:300, LEES SUMMIT, MO 64063600 SW JEFFERSON ST, Unit:301,  
LEES SUMMIT, MO 64063600 SW JEFFERSON ST, Unit:203, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	John Borns	Failed	Thursday, May 14, 2015
Corrective Action Required 1 Misc 1		RATED ASSEMBLIES AT CORRIDOR DOOR RECESSES TO BE INSPECTED WHEN READY.	
Corrective Action Required 2 Misc 1		SOME UNITS OF SAFETY GLASS YET TO BE INSTALLED AND APPROVED.	
Corrective Action Required 3 Misc 1		WORK IN PROGRESS AT ELECTRICAL ROOM. ALL ELEMENTS SUBJECT TO APPROVAL WHEN ALL READY FOR INSPECTION.	
Corrective Action Required 4 Misc 1		ELECTRICAL RECEPTACLES AT DEMOUNTABLE OFFICE CUBICLES SUBJECT TO TEST & APPROVAL WHEN READY.	
Corrective Action Required 5 Misc 1		ENSURE ALL ELECTRICAL RECEPTACLES ARE SECURED SOLID TO BOXES. NON "SOFT" OR LOOSE SIDE-TO-SIDE.	
Corrective Action Required 6 Misc 1		RESOLVE ANY FIRE DEPARTMENT ISSUES.	
Corrective Action Required 7 Misc 1		ELECTRICAL PANEL SCHEDULE(S) SUBJECT TO APPROVAL. ENSURE ALL LABELING IS CURRENT, SPECIFIC, AND LEGIBLE.	

<b>Occupancy Inspection - Fire</b>	Joe Dir	Not Ready	Thursday, May 14, 2015
--	---------	-----------	------------------------

**Comments:**