

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20150837, Building Permit - Commercial  
Address: 1174 NE DOUGLAS ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Plumbing Inspection - Commercial</b>	John Borns	Partial	Friday, May 15, 2015

Partial Correction  
1      Misc 1

OK TO COVER WHEN READY UNDER-SLAB PVC SANITARY DRAIN, WASTE, &  
VENT PIPING AT BREAK/UTILITY AND CORRIDOR.

NOT READY AT WEST RESTROOM. CALL FOR RE-INSPECTION ON SUBSEQUENT  
BUSINESS DAY.

NOTE IPC 312 / IRC P2503.5.1 REQUIREMENT FOR PRESSURE-TESTING PIPING  
SYSTEM.

**Comments:**