

Temporary Certificate of Occupancy

Permit #: PRCOM20150051
Address: 200 NE MISSOURI RD, Unit:200, LEES SUMMIT, MO 64064
Inspected On: Monday, May 18, 2015
Inspected By: John Borns
Expiration Date: 6/4/2015 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Temporary C of O	Monday, May 18, 2015

Corrective Action Required:

1 Misc 1 RESOLVE FIRE DEPARTMENT ISSUES

Corrective Action Required:

2 Misc 1 CHECK ELECTRICAL PANELS. ENSURE PANEL SCHEDULES ARE CURRENT, COMPLETE, AS SPECIFIC AS POSSIBLE, AND LEGIBLE.