

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20143335, Building Permit - Commercial  
Address: 200 NE MISSOURI RD, Unit:100, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Partial	Tuesday, May 19, 2015
Partial Correction 1 Misc 1		ONE LAYER 5/8" TYPE X GWB TOP-OUT AT CORR A112 OUTSIDE A116 NORTH; SAME AT CORR A110 O/S A116 W; SAME @ A150 W, 152 W&S, ABOVE DOOR #A133b;	
Partial Correction 2 Misc 1		OK TO COVER WHEN READY COMPONENTS OF 2-HR FIRE-RATED WALLS AT LOCATIONS: TWO LAYERS 5/8" TYPE X GWB TOP-OUT AT CORR A112 OUTSIDE A114 SOUTH;	

**Comments:**