

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20151029, Building Permit - Commercial
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial	John Borns	Passed	Friday, May 22, 2015

Comments: SUBJECT SPACE WAS RENOVATED AND COMPLETED PRIOR TO APPLICATION FOR PERMIT. IN-WALL AND ABOVE CEILING WORK WAS NOT REQUESTED FOR INSPECTION AND NOT INSPECTED PRIOR TO BEING COVERED. EXTENT AND CONDITION OF CONCEALED SYSTEMS AND ELEMENTS ARE UNKNOWN. "FINAL" INSPECTION BY CODES ADMINISTRATION COMPRISED VISUAL INSPECTION OF FINISH WORK AND TESTING OF ELECTRICAL RECEPTACLES. CLOSE PERMIT.