



**LEE'S SUMMIT**  
**MISSOURI**



---

**FIRE DEPARTMENT**

**PLANS REVIEW CONDITIONS**

Permit No:	PRCOM20150014	Date:	May 27, 2015
Project Title:	JOHN KNOX VILLAGE COURTYARDS INDEPENDENT LIVING APARTMENTS	Applicant:	NATIONAL FIRE SUPPRESSION
Location:	508 NW MURRAY RD, LEES SUMMIT, MO 64081		501 SUNSHINE RD KANSAS CITY, KS 66115
Type of Work:		Primary:	(913) 321-9208
Occupancy Group:	R-2		
Description	NEW 4-STORY INDEPENDENT LIVING APARTMENT - (COMMONS AREA UNDER SEPARATE PERMIT) - NEW CONSTRUCTION REPLACES APARTMENTS PREVIOUSLY DEMOLISHED		
Construction Type:	Type VA (1 hour)		
Map Page:	195E		

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

**Sprinkler Plan Review**

**Reviewed By: Joe Dir**

**Released for Construction**

1. Provide a spare sprinkler head box equipped with spare sprinkler heads and a wrench.
2. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.  
  
Call 816-969-1300 to schedule hydrostatic pressure testing and acceptance flow tests
3. Air compressor for the dry system shall be a UL listed compressor for fire service.

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**