

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141079, Building Permit - Commercial
Address: 3361 SW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Mark Harding	Partial	Monday, June 01, 2015

Corrective Action Required

1	Misc 1	CORRIDORS 2-4 OK TO ROCK
---	--------	--------------------------

Corrective Action Required

2	Misc 1	ROUGH - IT WALLS / ELEVATOR 2HR WALLS OK FOR 1ST FLOOR 2ND FLOOR
---	--------	---

		1ST FLOOR 04,02,12- DRILLED JOIST, HOLES., D UNIT DROPS 2ND CHECK 2204,6,13 ,GOOGLE HOLES ALL LEVELS 3RD NOT READY
--	--	---

Corrective Action Required

3	FIRST FLOOR	UNITS-ONLY
---	-------------	------------

		GARAGE ROUGH INSPECTION HOLD DOWNS CLEAN OUTS CAULK
--	--	--

Corrective Action Required

4	SECOND FLOOR	TRUSS REPAIR FOR 3RD FLOOR TRUSS 2113 MISSING TRUSS REPAIR
---	--------------	---

Corrective Action Required

5	THIRD FLOOR	2300 TRUSS
---	-------------	------------

Corrective Action Required

6	FOURTH FLOOR	CORRIDOR OK TO ROCK NO UNITS INSPECTED
---	--------------	---

Comments:

