

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRRES20143054, Building Permit - Residential
Address: 4350 SW PRYOR RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Mark Harding Codes Residential		Failed	Tuesday, June 02, 2015

Corrective Action Required

1	Misc 1	<ul style="list-style-type: none">- PROVIDE APPROVAL FROM JACKSON COUNTY ON SEPTIC SYSTEM- PROVIDE APPROVAL FROM PUBLIC WORKS ON DRIVE WAY APPROACH-LOCKOUTS ON HARD WIRED APPLIANCES-LABEL SMOKE DETECTOR BREAKER- FINAL GRADE, SEEDING, SOD EROSION CONTROL.- PROVIDE ADDRESS AT ROAD.-SEAL BOTTOM OF BOX OUT IN GARAGE WITH APROVED MATERIAL.
---	--------	--

Comments: