

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20143406, Building Permit - Commercial

Address: 853 NW OBRIEN RD, LEES SUMMIT, MO 64081901 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	John Borns	Partial	Wednesday, June 03, 2015
Partial Correction 1 Misc 1		GROUTING OF CMU EXTERIOR WALL AT NEW OPENINGS INSPECTED IN PROGRESS -- COMPLETED, EXCEPT COULD NOT BE GROUTED AT TOP COURSE (SOLID BLOCK -- NOT CELLUAR).	
		5/28/15: WITNESSED EPOXY-SETTING OF ANCHOR BOLTS IN ANGLE LINTELS OVER HEADS OF TWO NEW STOREFRONT OPENINGS AT TUESDAY MORNING STORE.	
Partial Correction 2 Misc 1		OK TO COVER WHEN READY LIGHT-GAUGE STEEL FRAMING AT EXTERIOR BUILDING WALL AT NORTH END OF BUILDING;	

Comments: