



PLAN REVIEW CONDITIONS

June 04, 2015

SARAH PEPPER ENTERPRISES LLC
5925 WALNUT
KANSAS CITY, MO 64113

Permit No: PRCOM20151251
Project Title: JAMES A STUCKMEYER LLC
Project Address: 224 SW MAIN ST, LEES SUMMIT, MO 64063
Parcel Number: 61340223600000000
Location: LEES SUMMIT TOWN OF E 59.5' OF W 100' OF LOTS 1 & 2 BLK 6, & TH N 12.5' OF TH W41' OF LOT 2 BLK 6, ALL LOT3 BLK 6 & S 2 1/2' OF LOT 4
Type of Work: NEW TENANT FINISH
Occupancy Group:
Description: OFFICE SPACE FOR MEDICAL CONSULTING BUSINESS
MEDICAL RECORDS STORED ON SITE

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Fire Plan Review

Reviewed By: Brian Austerman

Approved

1. 2012 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building, each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

Provide addressing on front and rear doors, if not already existing

2. 2012 IFC 906.2 - General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

Provide a 5lb ABC type fire extinguisher

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.