

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141078, Building Permit - Commercial
Address: 3351 SW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Mark Harding	Failed	Tuesday, June 09, 2015

Corrective Action Required

1	Misc 1	<p>BUILDING #1 PRE-FINAL NOT COMPLETE LIST GARAGE LEVEL-EAST TO WEST- 1-HOLES IN CEILING 2,3,4,5, 6-ACCESS PANEL IN CEILING STORAGE ROOMS- 1,2,3,4 CAULK PLUMBING STACKS WHERE REQUIRED 7,8,9 CAULK. ELEVATOR EQUIPMENT ROOM-OUTLET COVER, CAULK, LABEL DISCONNECTS FIRE PILLOWS CONDUIT BETWEEN FLOORS ALL, Fire extinguishers all corridors. Label all doors , floor leves, equipment rooms, unit rooms, north stair tower label gate.</p> <p>1ST FLOOR-UNITS 1101 KIT ELECT, SINK 1102- KIT ELECT, SINK 1103- SINKS KIT. 1106-CHECK ALL 1105- KIT SINK 1108 - KIT ELECT, SINK 1110- PATIO BUBBLE COVER, ACCESS PANEL FURNACE 1112-PATIO GFCI 1109 CHECK ALL</p> <p>FLOOR#2 CHECK ALL- numerous breakers off throughout units for inspection. --Install all fire extinguishers, seal IT rooms.</p>
---	--------	--

Caulk elevator ground floor penetrations.
Gfci's west ground level at panel. Sprinkler room heater.
Check room top units and gfci's

Comments: