

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20150580, Building Permit - Commercial
Address: 910 NW BLUE PKWY, Unit:J, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Thursday, June 11, 2015

Partial Correction
3 Misc 1

OK TO TAPE, MUD, AND FIRE-SEAL ONE LAYER 5/8" TYPE X GWB AT PERIMETER INTERIOR FACE. COMPLETION OF PENETRATION SEALING SUBJECT TO APPROVAL.

Comments: