220 SE GREEN ST. P. O. BOX 1600

ADDRESS: 707 SW WARD RD unit B

PROPERTY OWNER: LORETTA COTTON

CITY OF LEE'S SUMMIT

CODES ADMINISTRATION

PHONE: 816-969-1200 FAX: 816-969-1201

Emergency Call-Out Inspection Report

TENANT:	
PHONE#: 816-982-3292	
Time of Call to respond: 9:49PM	
Time of Arrival on scene: 10:10PM	_
Description: Electrical Issue	
Location of Damages: Main electrical Panel rear of unit	_
Called y FD for electrical sparking at the main electrical panel.	
Panel cover was off and no power at time of inspection.	,
Main breaker was in the on position. Ac unit had been repaired days before. Circuit for AC unit needs to be correctly	
Color coded or re-wired. Appears Main disconnect is damaged. KCPL was dispatched and terminated power at the	
Meter.	
Owner to contact Licensed Electrician and repair issues. Re-inspection will be required for KCPL to restore power.	
Electrical Permit Required	
のでは本権を開発されていた。	
Gas Service:	
Electrical Service:	
Water Service:	
List of placards posted: inspected	
Permits required: electrical permit	
Time Departed: 10:45PM	
INSPECTOR: Mark Harding DATE: 6/10/15	