

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20150471, Building Permit - Commercial
Address: 410D SE 3RD ST, Unit:102A, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Partial	Wednesday, June 17, 2015

Partial Correction
1 Misc 1

PHASED FINAL..

**OK TO USE & OCCUPY PHASE 1 SPACES 103-114 EXCEPT PROCEDURE ROOMS
SUBJECT TO RE-INSPECTION WHEN EQUIPMENT IS INSTALLED.**

Occupancy Inspection - Fire	Joe Dir	Temporary C of O	Wednesday, June 17, 2015
------------------------------------	---------	------------------	--------------------------

Corrective Action Required
1 FD505.1 Address
Numbers.

New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In multi-tenant commercial buildings where tenants have multiple entrances located on different sides of the building, each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

Change the address of all doors leading into existing and new areas to be the same numerics of 102A

Comments: