

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20143407, Building Permit - Commercial

Address: 242 NW OLDHAM PKWY, LEES SUMMIT, MO 64081238 NW OLDHAM PKWY, LEES SUMMIT, MO 64081186 NW OLDHAM PKWY, LEES SUMMIT, MO 64081196 NW OLDHAM PKWY, LEES SUMMIT, MO 64081198 NW OLDHAM PKWY, LEES SUMMIT, MO 64081200 NW OLDHAM PKWY, LEES SUMMIT, MO 64081202 NW OLDHAM PKWY, LEES SUMMIT, MO 64081222 NW OLDHAM PKWY, LEES SUMMIT, MO 64081204 NW OLDHAM PKWY, LEES SUMMIT, MO 64081210 NW OLDHAM PKWY, LEES SUMMIT, MO 64081218 NW OLDHAM PKWY, LEES SUMMIT, MO 64081236 NW OLDHAM PKWY, LEES SUMMIT, MO 64081240 NW OLDHAM PKWY, LEES SUMMIT, MO 64081244 NW OLDHAM PKWY, LEES SUMMIT, MO 64081180 NW OLDHAM PKWY, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Commercial</b>	John Borns	Partial	Wednesday, June 17, 2015

Partial Correction  
1 Misc 1

OK TO POUR WHEN READY COLUMN FOOTING ENLARGEMENTS AT FOLLOWING COLUMN LINE LOCATIONS: **AJ; AK; BQ; BR.**  
**TOPS OF EXISTING FOOTINGS AT U & V ARE NEAR SIDEWALK SUBGRADE, SO ARE DEEMED NOT REQUIRED TO BE ENLARGED.**

Comments: