

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20143335, Building Permit - Commercial
Address: 200 NE MISSOURI RD, Unit:100, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Not Ready	Thursday, June 18, 2015
Partial Correction 1 Misc 1		ONE LAYER 5/8" TYPE X GWB TOP-OUT AT CORR A112 OUTSIDE A116 NORTH; SAME AT CORR A110 O/S A116 W; SAME @ A150 W, 152 W&S, ABOVE DOOR #A133b;	
Partial Correction 2 Misc 1		OK TO COVER WHEN READY COMPONENTS OF 2-HR FIRE-RATED WALLS AT LOCATIONS: TWO LAYERS 5/8" TYPE X GWB TOP-OUT AT CORR A112 OUTSIDE A114 SOUTH;	
Partial Correction 3 Misc 1		GWB AT 1 HR FIRE-RATED WALLS: OK TO TAPE, MUD, & FIRE-SEAL WHEN READY 5/8" TYPE X GWB INSTALLATION @ FOLLOWING LOCATIONS: A111 E & S; EXISTING LOBBY EAST WALL OPPOSITE A143;	
Partial Correction 4 Misc 1		CONSTRUCTION NOTED, BUT NOT SHOWN ON APPROVED DRAWINGS: FRAMING & 1" SHAFT LINER BOARD AT UPPER 4' OF EAST WALL OF SPACES 100/102/103.	
		REVISED DRAWINGS MUST BE SUBMITTED TO LS CODES ADMINISTRATION FOR APPROVAL AND INSERTION IN FIELD AND OFFICE SETS.	

Comments: