

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20143335, Building Permit - Commercial
Address: 200 NE MISSOURI RD, Unit:100, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Electrical Inspection - Commercial	John Borns	Partial	Friday, June 19, 2015

Partial Correction
1 Misc 1

OK TO COVER WHEN READY UNDER-SLAB ELECTRICAL CONDUIT & FLOOR BOXES AT: 4 CONDUITS FROM NURSE STATION TO 16' NORTH; AT PAIN MANAGEMENT ROOMS A139-A142; **NUMEROUS CONDUITS ENTERING BUILDING THROUGH 8" BORE THROUGH FOOTING AND EXTENDING TO VARIOUS LOCATIONS IN SPACES A117 & A118;**

Comments: