

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20150580, Building Permit - Commercial
Address: 910 NW BLUE PKWY, Unit:J, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Friday, June 19, 2015
Partial Correction 1 Misc 1		OK TO TAPE, MUD, AND FIRE-SEAL ONE LAYER 5/8" TYPE X GWB AT INTERIOR FACE OF PERIMETER WALLS. COMPLETION OF PENETRATION SEALING SUBJECT TO APPROVAL.	
Partial Correction 2 Misc 1		PERIMETER WALLS OF REAR (EAST) VESTIBULE ARE APPROVED AS BUILT AND FIRE-SEALED TO ROOF DECK BOTH FACES. OK TO CONSTRUCT (INCLUDING TAPE&MUD) WITHOUT ITERIM INSPECTION TWO-LAYER CEILING IN VESTIBULE PER A/E LTR DTD 6/9/15.	

Comments: