

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20150837, Building Permit - Commercial
Address: 1174 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Failed	Tuesday, June 23, 2015

Corrective Action Required

3	Misc 1	FINISH ELECTRICAL AT NE CORNER: LOOSE & "SOFT" RECEPTACLES
---	--------	--

Corrective Action Required

7	Misc 1	INSTALL SPARK RINGS AT RESTROOM ELECTRICAL RECEPTACLES TO CORRECT EXCESSIVE SET-BACK AND TO MAKE DEVICES SECURE.
---	--------	--

Corrective Action Required

9	Misc 1	NEC 110-22; 384-13; IRC E3606.2 LABELING OF ELECTRICAL CIRCUIT BREAKERS: EACH BREAKER MUST BE LABELED WITH REFERENCE TO SPECIFIC SPACE(S) OR EQUIPMENT SERVED. MUST BE LEGIBLE; SPECIFIC. NO DITTO MARKS OR CONTINUATION SYMBOLS FOR INDIVIDUAL BREAKERS. LABEL UNUSED BREAKERS "SPARE"
---	--------	---

PANEL SCHEDULE, AS NOW CREATED, IS UPSIDE--DOWN

Partial Correction

12	Misc 1	OCCUPANCY STATUS: OK TO SET UP FOR BUSINESS. NO PUBLIC OR PATIENTS BEFORE APPROVAL.
----	--------	--

Comments: