

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141072, Building Permit - Commercial
Address: 3301 SW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Mark Harding	Failed	Tuesday, June 23, 2015

Corrective Action Required

1 Misc 1

- pending approval from other departments
- pool will not be included in this inspection

Clubhouse-

- provide Grippable handrails for stairs, provide 1 1/2" clearance on west handrail to landing
- see other department comments for other outstanding issues

Approved for TCO- 4-22-15

Comments: