

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20142569, Building Permit - Commercial  
Address: 3301 SW KESSLER DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

|                                                       |              |          |                        |
|-------------------------------------------------------|--------------|----------|------------------------|
| Inspection:                                           | Inspector:   | Outcome: | Date:                  |
| <b>Final Building<br/>Inspection -<br/>Commercial</b> | Mark Harding | Failed   | Tuesday, June 23, 2015 |

### Corrective Action Required

1 Misc 1

### POOL FINAL CODES ONLY-

FENCEING REQUIREMENTS - COMPLY TO CODE, OPENINGS OVER 4"  
COMBUSTION AIR FOR HEATER ROOM  
BLOW OFF PIPING FOR POOL HAETERS  
EMERGENCY SHUT OFF SIGNAGE  
GAS PIPING- CONNECTION INTO BUILDING FOR POOL GRILLS.  
BBQ GRILLS, ISLAND , FRAMING, ETC INCOMPLETE(NOT STARTED).

### Comments: