

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141072, Building Permit - Commercial
Address: 3301 SW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Commercial	Mark Harding	Partial	Tuesday, June 23, 2015

Corrective Action Required

1	Misc 1	GAS PIPE INSPECITON- open pipe in pool heater room. flue clearance to pool heaters at exterior wall. ** no connection from gas line in room to pool bbq grills, grills not installed GAS CAPPED AT POOL ROOM NO CONNECTION TO GRILLS TO OUTSIDE WALL
---	--------	--

Corrective Action Required

2

Occupancy Inspection - Codes Commercial	Mark Harding	Failed	Tuesday, June 23, 2015
--	--------------	--------	------------------------

Corrective Action Required

1	Misc 1	- pending approval from other departments - pool will not be included in this inspection Clubhouse- - provide Grippable handrails for stairs, provide 1 1/2" clearance on west handrail to landing -see other department comments for other outstanding issues Approved for TCO- 4-22-15
---	--------	---

Comments: