

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141076, Building Permit - Commercial
Address: 3331 SW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Mark Harding	Failed	Tuesday, June 23, 2015

Corrective Action Required

1 FRAMING/STRUCTURE OK TO ROCK THE FOLLOWING-
ELECATOR SHAFT 1-3

WEST GARAGE EVE OK TO COVER
EAST 1ST FLOOR PATIOS OK

Corrective Action Required

2 FIRST FLOOR

Corrective Action Required

3 SECOND FLOOR

Corrective Action Required

4 THIRD FLOOR

3301-BROKEN TRUSS KITCHEN ISLAND
3302-ELECTRICAL TO PORCH CUT STUDS, BROKEN FLOOR TRUSS OVER
ENTRY.
INSTALL CORRIDOR ELECTRICAL 3RD FLOOR
3303-TRUSS CENTER LIVING ROOM BROKEN, TRUSS REPAIR HVAC THROUG

Corrective Action Required

5 FOURTH FLOOR

DRYER VENTS , COMPLETE
3400 DRYER VENT SCREW
LINE SETS, WIRE BATH FANS CALUK ALL ROOF DRAINS, 3406 CAULK PLMB
3410 PUDDY
3412 ROCK FIRE LINE PUDY
INCOMPLETE INSPECITON NUMEROUS ITEMS RECALL

6/23 INCOMLETE

Comments: