

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20143335, Building Permit - Commercial
Address: 200 NE MISSOURI RD, Unit:100, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	John Borns	<u>Passed</u>	Tuesday, June 23, 2015

Footing Inspection - Commercial	John Borns	Failed	Tuesday, June 23, 2015
--	------------	--------	------------------------

Corrective Action Required

1 Misc 1

CORNER BARS MUST BE FULL SIZE

Corrective Action Required

2 Misc 1

SPLICES MUST BE 40 DIAMETERS

Corrective Action Required

3 Misc 1

3" RE-BAR CLEARANCE REQUIRED AT BOTTOMS AND BANKS

Comments: