

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20150837, Building Permit - Commercial
Address: 1174 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Failed	Wednesday, June 24, 2015

Corrective Action Required

1	Misc 1	FINISH ELECTRICAL AT NE CORNER: LOOSE & "SOFT" RECEPTACLES
---	--------	--

Corrective Action Required

2	Misc 1	NEC 370-20: INSTALL SPARK RINGS AT RESTROOM ELECTRICAL RECEPTACLES TO CORRECT EXCESSIVE SET-BACK AND TO MAKE DEVICES SECURE.
---	--------	--

Partial Correction

4	Misc 1	OCCUPANCY STATUS: OK TO SET UP FOR BUSINESS. NO PUBLIC OR PATIENTS BEFORE APPROVAL.
---	--------	---

Comments: