

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141076, Building Permit - Commercial
Address: 3331 SW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Mark Harding	Partial	Wednesday, June 24, 2015

Corrective Action Required

1 FRAMING/STRUCTURE

OK TO ROCK THE FOLLOWING-
ELECATOR SHAFT 1-3

WEST GARAGE EVE OK TO COVER
EAST 1ST FLOOR PATIOS OK

corridors 1-4 ok to cover , 3-4 th floors fire wire line will be on fac and atiiic on
the 4th

Corrective Action Required

2 FIRST FLOOR

Corrective Action Required

3 SECOND FLOOR

Corrective Action Required

4 THIRD FLOOR

3301-BROKEN TRUSS KITCHEN ISLAND
3302-ELECTRICAL TO PORCH CUT STUDS, BROKEN FLOOR TRUSS OVER
ENTRY.
INSTALL CORRIDOR ELECTRICAL 3RD FLOOR
3303-TRUSS CENTER LIVING ROOM BROKEN, TRUSS REPAIR HVAC THROUG

Corrective Action Required

5 FOURTH FLOOR

DRYER VENTS , COMPLETE
3400 DRYER VENT SCREW
LINE SETS, WIRE BATH FANS CALUK ALL ROOF DRAINS, 3406 CAULK PLMB
3410 PUDDY
3412 ROCK FIRE LINE PUDY
INCOMPLETE INSPECITON NUMEROUS ITEMS RECALL

Corrective Action Required
6

6/23 INCOMPLETE

Comments: