

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20150463, Building Permit - Commercial
Address: 1740 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Failed	Thursday, June 25, 2015

Corrective Action Required
1 Misc 1

IMC 507.16 COMMERCIAL KITCHEN GREASE HOOD PERFORMANCE TEST:
NEBB-CERTIFIED REPORT REQUIRED TO BE SUBMITTED TO INSPECTOR WHEN
EQUIPMENT IS OPERATIONAL AND BEFORE COMMERCIAL USE. SMOKE
CAPTURE TEST TO BE CERTIFIED BY 3RD PARTY OR WITNESSED BY INSPECTOR
BEFORE ANY USE IS APPROVED.

Corrective Action Required
8 Misc 1

SEAL MOP SINK TO WALL.

Corrective Action Required
11 Misc 1

**OK TO SET UP FOR BUSINESS. NO PUBLIC ENTRY OR BUSINESS OPERATIONS
PRIOR TO APPROVAL.**

Corrective Action Required
13 Misc 1

ROOFTOP: DESIGNATE THE TWO GREASE HOOD EXHAUST FANS AND REFLECT
DESIGNATIONS AT ELECTRICAL PANEL.

Comments: