

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20143335, Building Permit - Commercial
Address: 200 NE MISSOURI RD, Unit:100, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Foundation Inspection - Commercial	John Borns	Partial	Monday, June 29, 2015

Partial Correction
1 Misc 1

OK TO POUR WHEN READY 5" THICK EQUIPMENT SLAB AT 1.2/A.5 PREPED
WITH MAT OF #4 REBAR AT MID-DEPTH @ 16" O/C E/W

Comments: