

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20141078, Building Permit - Commercial  
Address: 3351 SW KESSLER DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Mark Harding	Partial	Monday, June 29, 2015

### Corrective Action Required

1	Misc 1	APPROVED FOR TCO - SEE OTHER DEPARTMENTS FOR APPROVAL UNITS APPROVED 1ST FLOOR -1101,1102 ONLY 2 UNITS WITH OUT KITCHEN CABINETS AND COUNTERS. 2ND FLOOR-2 EAST END UNITS- OTHER OK NO INSPECTION ON 3,4 FLOORS  NOT TO OCCUPY ANY UNITS -4TH FLOORS ALL STAIRWAYS AND CORRIDORS MUST REMAIN CLEAR FOR OCCUPANTS. PER FD NO PARKING IN GARAGES UNIT SMOKES OR WORKING CORRECTLY.
---	--------	--

### Corrective Action Required

2	Misc 1	Occupancy inspection for 1078 3351 sw kesseln. 1st floor model was complete, 1102 no cabinets or counter/sink. 2nd floor was incomplete 2-end units. 1202 faucet was in but drainage was incomplete. 1201 same
---	--------	---

### Corrective Action Required

3	Misc 1	3RD FLOOR- ALL UNITS OK.
---	--------	-----------------------------

### Comments: