

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20141079, Building Permit - Commercial  
Address: 3361 SW KESSLER DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Mark Harding	Failed	Thursday, July 02, 2015

Corrective Action Required  
1 Misc 1

above ceiling failed d 1 units 1,2,3.

HVAC 2 LAYER AT ELEVATOR WALL NEED FIXED. SUPPORT DVW SOUTH END AND FIRECAULK PENETRATIONS.  
3RD FLOOR CORRIDORS PATCH HOLES FOR SPLRINK  
#1 1ST FLOOR SPRINKLER LINE DROPS AND PLUMBING

**Comments:**