

# Temporary Certificate of Occupancy

---

**Permit #:** PRCOM20141078  
**Address:** 3351 SW KESSLER DR, LEES SUMMIT, MO 64081  
**Inspected On:** Thursday, July 02, 2015  
**Inspected By:** Mark Harding  
**Expiration Date:** 7/16/2015 12:00:00 AM

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Mark Harding	Temporary C of O	Thursday, July 02, 2015

**Corrective Action Required:**

1	Misc 1	APPROVED FOR TCO ALL STAIRWAYS AND CORRIDORS MUST REMAIN CLEAR FOR OCCUPANTS. PER FD NO PARKING IN GARAGES UNIT SMOKES OR WORKING CORRECTLY. 1,2,3,4 FLOORS APPROVED TO OCCUPY. CLEAN ROOF TOP. CHECK LIQUID TIGHT TO DSS UNIT AT ROOFTOP. FIX THRESHOLD HEIGHT AT NORTH DOOR 1ST FLOOR.
---	--------	---

**Corrective Action Required:**

2	Misc 1
---	--------

**Corrective Action Required:**

3
---

