PLANNING AND CODES ADMINISTRATION DEPARTMENT 220 SE GREEN STREET LEE'S SUMMIT, MO 64063 (816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141076, Building Permit - Commercial Address: 3331 SW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

All Rough Inspection - Mark Harding Partial Thursday, July 02, 2015

Commercial

Corrective Action Required

1 FRAMING/STRUCTURE

Corrective Action Required

2 FIRST FLOOR APPROVED

Corrective Action Required

3 SECOND FLOOR

APPROVED

Corrective Action Required

4 THIRD FLOOR

3301-BROKEN TRUSS KITCHEN ISLAND

3302-ELECTRICAL TO PORCH CUT STUDS, BROKEN FLOOR TRUSS OVER

ENTRY.

INSTALL CORRIDOR ELECTRICAL 3RD FLOOR

3303-TRUSS CENTER LIVING ROOM BROKEN, TRUSS REPAIR HVAC THROUG

Corrective Action Required

5 FOURTH FLOOR ROUGH APPROVED

Comments: