



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20150741	Date:	July 07, 2015
Project Title:	VICTORIA'S SECRET AT SUMMIT FAIR	Applicant:	
Location:	860 NW BLUE PKWY, Unit:P, LEES SUMMIT, MO 64086	ABSOLUTE FIRE INC 13906 CENTURY LN GRANDVIEW, MO 64030	
Type of Work:		Primary: (816) 737-9991	
Occupancy Group:	M		
Description:	TENANT FINISH FOR NEW CLOTHING STORE		
Construction Type:	Type IIB (Unprotected)		
Map Page:	195A		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Joe Dir

Released for Construction

1. Isolation valves will be addressed according to suite designation and monitored at the FACP
Flow test required, call 816-969-1300 to schedule a test.
verified at inspection

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.