



**LEE'S SUMMIT**  
MISSOURI



**FIRE DEPARTMENT**

**PLANS REVIEW CONDITIONS**

Permit No:	PRCOM20150580	Date:	July 07, 2015
Project Title:	TORRID	Applicant:	
Location:			
	910 NW BLUE PKWY, Unit:J, LEES S UMMIT, MO 64086	ABSOLUTE FIRE INC 13906 CENTURY LN GRANDVIEW, MO 64030	
Type of Work:			
Occupancy Group:	M		
Description:	TENANT FINISH FOR CLOTHING SALES	Primary: (816) 737-9991	
Construction Type:	Type IIB (Unprotected)		
Map Page:	195A		

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

**Sprinkler Plan Review**

**Reviewed By: Joe Dir**

**Released for Construction**

1. Isolation valve will be addressed according to suite designation and monitored at the FACP.  
Flow test required, call 816-969-1300 to schedule a test  
verified at inspection

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**