



PLANS REVIEW CONDITIONS

Permit No:	PRCOM20150580	Date:	July 07, 2015
Project Title:	TORRID	Applicant:	
Location:			
910 NW BLUE PKWY, Unit:J, LEES SUMMIT, MO		<NO CONTACT NAME AVAILABLE>	
64086		<NO CONTACT INFORMATION AVAILABLE>	
Type of Work:			
Occupancy Group:	M		
Description:	TENANT FINISH FOR	<NO CONTACT NAME AVAILABLE>	
CLOTHING SALES		<NO CONTACT INFORMATION AVAILABLE>	
Construction Type:	Type IIB (Unprotected)		
Map Page:	195A		
		<NO CONTACT NAME AVAILABLE>	
		<NO CONTACT INFORMATION AVAILABLE>	
		<NO CONTACT NAME AVAILABLE>	
		<NO CONTACT INFORMATION AVAILABLE>	

KANSAS CITY FIRE AND SECURITY LLC
901 E LOULA ST
OLATHE, KS 66061

Primary: (913) 780-5237

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Joe Dir

Released for Construction

1. Flow switch and tamper / isolation valve to be addressed at the FACP according to suite designation.
verified at inspection
alarm test required call 816-969-1300 to schedule a test.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.