

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20151379, Building Permit - Commercial
Address: 228 NW MCNARY CT, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Passed	Wednesday, July 08, 2015
Underslab Electrical Inspection - Commercial	John Borns	Passed	Wednesday, July 08, 2015

Comments: OK TO COVER WHEN READY UNDER-SLAB ELECTRICAL CONDUIT & FLOOR BOX @ OFFICE 106. OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING + IN-WALL SYSTEMS AFTER ROUGH-IN IS COMPLETED FOR EMERGENCY LIGHT AS SHOWN ON APPROVED DRAWING.

HEADS-UP IN ADVANCE FOR ABOVE-CEILING INSPECTION:

- PLACE/REPLACE NO CEILING TILE BEFORE INSPECTION. PROVIDE 8'+ LADDER. REMOVE ALL ABANDONED MATERIALS (INCLUDING UN-USED LOW-VOLTAGE CABLE) OTHER THAN HANGER WIRES; BEND UNUSED HANGER WIRES UP TO CLEAR GRID MINIMUM 18".**
- PER ICC A117.1: ACCESSIBLE RESTROOMS REQUIRE SIDEWALL GRAB BARS; WATER CLOSET FLUSH HANDLES MUST BE ON FREE SIDE OF TANK.**