



**LEE'S SUMMIT**  
MISSOURI



**FIRE DEPARTMENT**

**PLANS REVIEW CONDITIONS**

Permit No: PRCOM20150781 Date: July 09, 2015  
Project Title: SKYZONE TRAMPOLINE PARK Applicant:  
Location: 2821 NE MCBAIN DR, ADVANTAGE FIRE PROTECTION SYSTEMS INC  
LEES SUMMIT, MO 64064 404 B NW 11TH ST  
BLUE SPRINGS, MO 64015  
Type of Work:  
Occupancy Group: A-4  
Description: TENANT FINISH FOR INDOOR TRAMPOLINE GYMNASIUM WITH PARTY ROOMS AND  
FOOD SERVICE  
Construction Type: Type IIB (Unprotected)  
Map Page: 175R

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

**Sprinkler Plan Review**

**Reviewed By: Joe Dir**

**Released for Construction**

1. Hydrostatic test required, call 816-969-1300 to schedule a test
  2. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.
- Flow test required call 816-969-1300 to schedule a test

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**