

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRRES20150890, Building Permit - Residential
Address: 3928 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	Khanh Nguyen	Failed	Thursday, July 09, 2015

Corrective Action Required

1	Misc 1	-ONLY THE BASEMENT FOOTING OK TO POUR. GARAGE FOOTING WILL BE DONE LATER
		-WALLS BETWEEN THIS HOUSE AND THE ONE ON THE SOUTH SIDE APPEAR TO BE LESS THAN TEN FT APART. CODE REQUIRES 1 HR RATING ON THE WALLS AND THE SOFFIT. PROVIDE MINIMUM TEN FT SEPARATION DISTANCE BETWEEN HOUSES

Comments: