

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRRES20150890, Building Permit - Residential
Address: 3928 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	Khanh Nguyen	Passed	Friday, July 10, 2015

Comments:

-THE FOOTING ON THE SOUTH SIDE WAS SHIFTED NORTH 2" PLUS THE FOUNDATION WALL IS ALSO SHIFTED 1" NORTH TO PROVIDE A TOTAL OF 3" WALL SHIFT TO MEET THE TEN FT SEPARATION REQUIREMENT