

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20141076, Building Permit - Commercial  
Address: 3331 SW KESSLER DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Mark Harding	Partial	Friday, July 10, 2015

### Corrective Action Required

1	Misc 1	1ST LAYER BUILDING #3- STAIR WALLS GARAGE WALLS/STORAGE WALLS. 2HR WALLS-1ST LAYER - TUB WALLS - 1, 2 AND 3 FLOORS 2nd layers ok 1st layer elevator wall inside ok 2ND LAYER UNIT SIDE 1-2 ok to rock corridor ceiling only 6/24/15 2ND LAYER ELEVATOR SHAFT, UNIT SIDE 2ND FLOOR; 2ND LAYER WALLS ELEVATOR SHAFT; 1ST LAYER CEILING ELEVATOR SHAFT; 3RD FLOOR WALLS & CEILING; 2ND LAYER @ 2 HR CONDITIONS STAIR TOWERS
Partial Correction		
2	FOURTH FLOOR	FIRST LAYER LID NEEDS DAMPERS IN MECH PENETRATIONS SCREW PATTERN FIRST LAYER APPROVED.
Corrective Action Required		
3	THIRD FLOOR	FIRST LAYER LID APPROVED 2nd layer corridor walls-ok
Corrective Action Required		
4	SECOND FLOOR	FIRST LAYER LID APPROVED 2ND LAYER

**Comments:**