

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20141079, Building Permit - Commercial  
Address: 3361 SW KESSLER DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Mark Harding	Partial	Friday, July 10, 2015

Corrective Action Required

1	FIRST FLOOR	UNITS-ONLY 6/17;6/18 -CAULK ROOF DRAINS AT PLATE LINE -HVAC CORRIDOR , 2LAYERS OF ROCK COMPROMISED FOR HVAC THROUGH WALL -CAULK ROOF DRAIN G7 G8- CLEAN OUT G8 ANCOR BOLTS
---	-------------	--

Corrective Action Required

2	SECOND FLOOR	COMPLETE
---	--------------	----------

Corrective Action Required

3	THIRD FLOOR	COMPLETE
---	-------------	----------

Corrective Action Required

4	Misc 1	PRE ROUGH
---	--------	-----------

**Comments:**