

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20150580, Building Permit - Commercial  
Address: 910 NW BLUE PKWY, Unit:J, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	John Borns	Failed	Monday, July 13, 2015

Corrective Action Required

1	Misc 1	DESIGNATE THE TWO ELECTRICAL PANELS PER DRAWING WITH LABEL ON PANEL FRONT.
2	Misc 1	CORRECT ELECTRICAL PANEL SCHEDULES
3	Misc 1	SUPPORT CANTILEVERED END OF EXISTING GAS PIPE ABOVE CORRIDOR AT REAR
4	Misc 1	SEAL WATER CLOSET TO FLOOR.
5	Misc 1	<b>OCCUPANCY STATUS: OK TO SET UP FOR BUSINESS. NO CUSTOMERS OR PUBLIC BEFORE COFO APPROVAL.</b>

Comments: