

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20150741, Building Permit - Commercial
Address: 860 NW BLUE PKWY, Unit:P, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Partial	Monday, July 13, 2015

Partial Correction
1 Misc 1

OK TO COVER WHEN READY GWB CEILING FRAMING + ABOVE-CEILING
SYSTEMS @ FOLLOWING SPACES: **TRANSITION SOFFITS #2, 3, 4; CASHWRAP;
QUEUING ZONE; FITTING ROOMS; VESTIBULE A #2; WOMENS RR; OFFICE;**

**COMPLETE TOP CHORD AND CHECK SPLICES AT BULKHEAD BEAM AT
TRANSITION #5. DO NOT COVER.**

Comments: