

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20141080, Building Permit - Commercial  
Address: 3371 SW KESSLER DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Mark Harding	Failed	Monday, July 13, 2015

### Corrective Action Required

1	LOWER LEVEL	4012-VALVES, PEX SUPPORT, SECURE ROMEX FROM EXTERIOR TO BATH, PLATE BOLT SOUTH WALL 3' DRAIN THROUGH CONCRETE WALL/ 4008 -4' ROOF DRAIN, LINE SET CAULK, PUDDY PADS, 4006-PUDDY, BATH VENT, LINE SETS., REMOVE DRYER BOX 4004 - FAN, DRYER CAULK, DRYER VENT, SEPERATE SPACE TO SPACE. 4002 LINE SET, PUDDY, FAN, 4000 LINE SETS CAULK TRUCK LINE INCOMPLETE -
---	-------------	--

### Comments: