

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141076, Building Permit - Commercial
Address: 3331 SW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Mark Harding	Partial	Monday, July 13, 2015

Corrective Action Required
1 Misc 1

2ND LAYER CEILING - 4TH FLOOR; 1ST LAYER WALLS 4TH FLOOR; 2ND LAYER 3RD FLOOR 2 HR CONDITIONS; 2ND LAYER ELEVATOR CEILING; 1ST LAYER 2 HR CONDITIONS FLOOR LANDINGS SOUTH STAIR TOWERS FLOORS 1 & 2

Partial Correction
2 FOURTH FLOOR

FIRST LAYER LID NEEDS DAMPERS IN MECH PENETRATIONS
SCREW PATTERN FIRST LAYER APPROVED.

Corrective Action Required
3 THIRD FLOOR

FIRST LAYER LID APPROVED
2nd layer
corridor walls-ok

Corrective Action Required
4 SECOND FLOOR

FIRST LAYER LID APPROVED
2ND LAYER

Comments: