

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20151156, Building Permit - Commercial
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---------------------------------------|------------|---|------------------------|
| In-wall Inspection | John Borns | Partial | Tuesday, July 14, 2015 |
| Partial Correction 1 Misc 1 | | OK TO TOP-OUT WALLS 4' WITH GWB TO ALLOW INSTALLATION OF HVAC DUCT AND OTHER SYSTEMS AT FOLLOWING LOCATIONS: (C)/(3) TO (C)/(4.5); (B.3)/(3) TO (C.1)/(3); (B)/(2.8) TO (B)/(4.5); | |
| Partial Correction 2 Misc 1 | | OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING + IN-WALL SYSTEMS AT FOLLOWING SPACES: 5A015A; | |

Comments: