

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRRES20151229, Building Permit - Residential
Address: 404 SE MILL CREEK DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Mike Copeland	Passed	Wednesday, July 15, 2015

Water Service Inspection - Residential	Mike Copeland	Failed	Wednesday, July 15, 2015
---	---------------	--------	--------------------------

Corrective Action Required
1 Misc 1

WATER METER NOT SET. NO GRAVEL IN PIT.

Comments: