

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141077, Building Permit - Commercial
Address: 3341 SW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Mark Harding	Partial	Friday, July 17, 2015

Corrective Action Required

1	THE FOLLOWING AREAS ARE APPROVED	1ST LAYER INSIDE ELEVATOR ELEVATOR CEILING-1ST, SOUTH TOWER 1ST LAYER
---	-------------------------------------	---

Comments: