

**CODES ADMINISTRATION**

**PLAN REVIEW CONDITIONS**

July 21, 2015

MARK ONE ELECTRIC CO INC  
909 TROOST AVE  
KANSAS CITY, MO 64106

Permit No: PRCOM20151580  
Project Title: LEES SUMMIT HOSPITAL ELECTRIC CAR CHARGING STATIONS  
Project Address: 2100 SE BLUE PKWY, LEES SUMMIT, MO 64063  
Parcel Number: 60420990900000000  
Location: HCA MIDWEST, LOTS 1A & 1B---LOT 1A  
Type of Work: NEW OTHER (COMMERCIAL)  
Occupancy Group:  
Description: ELECTRIC CAR CHARGING STATIONS

***Revisions Required***

***One or more departments have not approved the permit and the following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and provide three (3) copies of any revised sheets and/or additional information. Please contact the appropriate department regarding clarification of comments.***

Planning and Codes Administration (816) 969-1200

Fire Department (816) 969-1300

**Licensed Contractors**

**Reviewed By: Joe Frogge**

**Approved**

**Building Plan Review**

**Reviewed By: Joe Frogge**

**Rejected**

1. The charging station location is ok, but the mid span 25kVA OH TX pole appears to be too close to a 20" and a 12" water line. They will need to locate this pole a minimum of ten (10) feet from any of these water lines.

Action required: propose alternate location or verify (via official locate) that current location is compliant. Contact Gene Williams with questions - 816.969.1800.

***The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.***