

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20141924, Building Permit - Commercial  
Address: 615 SW 3RD ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Final Mechanical Inspection - Commercial</b>	John Borns	Passed	Tuesday, July 21, 2015

**Comments: CLOSE PERMIT. ON FUTURE INSTALLATIONS...**

**1) NEC 210.63 ELECTRICAL RECEPTACLE OUTLETS REQUIRED WITHIN 25 FEET OF HVAC AND/OR REFRIG EQPMT.**

**2) IFGC 404.8: METALLIC PIPING EXPOSED TO WEATHER MUST BE PERMANENTLY PROTECTED WITH PAINT OR BY OTHER APPROVED MEANS.**